



MacAllister Machinery Company, Inc.
7515 East 30th Street
P.O. Box 1941
Indianapolis, Indiana 46206
(317) 545-2151

CUSTOMER: USED EQUIP **SITE:** HQ YARD **Job#** 1166

<u>X</u>	1. Eng. Oil Level	<u>X</u>	4. Safety ground connected
<u>X</u>	2. Coolant Level	<u>X</u>	5. Circuit breaker open (off)
<u>X</u>	3. Generator and load bank connected for proper volts		

Test Date:	03/31/26
Tested By:	Myles Patrick
Title:	TECHNICIAN
Tested At:	100%
Ambient Temp:	74

Engine Model:	C27	Serial Number:	DWB00394	KW:	750
Generator Mfg/Model:	CAT/SR4B	Serial Number:	AFK00959	PF:	1
Control Panel Mfg:	CAT	Serial Number:	EMCP3.2		

Low Oil Pressure:	<u>30</u>	PSI	Overspeed:	<u>2124</u>	RPM:	<u>1800</u>
Hi Water Temp:	<u>225</u>	°F	Hours Before:	<u>111</u>	Hours After:	<u>112</u>

Test Load/Duration: 1HOURS 15 Min. Record Intervals

[illegible]

MacAllister Engine Power Approval:

By: _____

Title: TECH _____

DUCTS

1482

[illegible][illegible]

